



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer,Purulia**  
**West Bengal Fire & Emergency Services**  
**Purulia Fire Station, Ranchi Road,Purulia, Pin:- 723101**

Memo no.:FSR/0125186231600027

Date: 28-04-2023

**From:**  
**Divisional Fire Officer,Purulia**  
**West Bengal Fire & Emergency Services**

**To: Haladhar Mahato Teachers Training Institute (B. Ed.)**  
**Vill Dighi,P.O Dighi,P.S Boro, Dist Purulia, Pin723131**

**Sub: Issuance of Fire Safety Certificate for the existing construction of G+1 storied building under group Educational in favour of 'Haladhar Mahato Teachers Training Institute (B. Ed.),' at the premises no. Vill Dighi, JL no. 245, RS KH no. 38, RS Plot no. 3387,3388, P.O. Dighi, P.S. Boro, Dist Purulia, PIN723131, West Bengal.**

This is in reference to your application no. 0125189231600017 dated 19-04-2023 regarding the Issuance of Fire Safety Certificate for the existing construction of G+1 storied building under group Educational in favour of 'Haladhar Mahato Teachers Training Institute (B. Ed.),' at the premises no. Vill Dighi, JL no. 245, RS KH no. 38, RS Plot no. 3387,3388, P.O. Dighi, P.S. Boro, Dist Purulia, PIN723131, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of fire appliances.  
No parking will be allowed on the drive way.
2. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be maintained strictly.
3. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
4. A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.
5. The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.
6. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all teachers, employees and students of the building.
8. A crew of trained Fireman under the experienced officer shall be maintained round the

clock for safety of the building.

9. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.

10. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

11. Adequate nos. of Fire Safety Directional Signage's Board and Assembly Point shall be prepared and be displayed at all appropriate places of the building.

12. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.

13. Directional sign of escape route shall be displayed prominently.

14. This Fire Safety certificate is valid for three years and has to be renewed every three years from the date of issue of this letter.

Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the FSC shall be treated cancelled.

Signature valid

Digitally Signed.  
Name: PLABAN@CDAS  
Date: 28-Apr-2023 09:08  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Purulia  
West Bengal Fire & Emergency Services

Memo No.: FSR/0125186231600027